

# 320 AMP PEDESTAL

ALL CONDUCTOR CUAL COVERED AND SUNLIGHT RESISTANT  
**DISCLAIMER: MEMBER SHOULD CONTACT A LICENSED ELECTRICIAN FOR PROPER WIRE SIZE**

6 FT OF WIRE OUT OF WEATHERHEAD

35 FT POLE - 20 FT OF 3" CONDUIT

40 FT POLE - 25 FT OF 3" CONDUIT

45 FT POLE - 30 FT OF 3" CONDUIT

MEMBER WILL FURNISH AND INSTALL METER BASE,  
CONDUIT, WEATHERHEAD, DITCH, WIRE AND  
STRUCTURE TO MOUNT THE METER BASE

MINIMUM SCHEDULE 40 PVC

10 F.T. MINIMUM

GROUND LEVEL

2 F.T.

DRIVEN GROUND REQUIRED AT METER

TYPES OF CONDUIT: ELECTRICAL NON METALLIC

PVC-SCHEDULE 40 MINIMUM

