



HEART OF TEXAS ELECTRIC COOPERATIVE

DISPATCH: (254) 840-5100

APPOINTMENTS: (254) 840-5138

320 AMP PEDESTAL GUIDE

**ALL CONDUCTOR
CU/AL COVERED AND
SUNLIGHT RESISTANT**

**6 FT OF WIRE OUT OF
WEATHERHEAD**

- **35 FT POLE - 20 FT OF 3" CONDUIT**
- **40 FT POLE - 25 FT OF 3" CONDUIT**
- **45 FT POLE - 30 FT OF 3" CONDUIT**

← PVC-SCHEDULE 40 MINIMUM

**← 10 - 15 FT
FROM POLE →**

**MINIMUM OF 2
FEET DEEP**

**DRIVEN GROUND
REQUIRED AT METER**

**TYPE OF CONDUIT: ELECTRICAL NON-METALLIC
PVC-SCHEDULE 40 MINIMUM**

- **DISCLAIMER: MEMBER SHOULD CONTACT A LICENSED ELECTRICIAN FOR PROPER WIRE SIZE**
- **ALL POWER POLES ARE PROVIDED BY HOTEC, NO EXCEPTIONS**

MEMBER WILL FURNISH AND INSTALL:

- **METER BASE**
- **MAIN DISCONNECT**
- **CONDUIT**
- **WEATHERHEAD**
- **DITCH**
- **WIRE**
- **STRUCTURE TO MOUNT THE METER BASE**